

BRANZ Technical Opinion

Summary

This is to certify that the product described below has been examined by BRANZ Ltd on behalf of

Nu-Age Plaster Ltd
P O Box 195
Matamata

Test standard: AS3700-2011 Appendix D6 (Bond strength)
NZS 3112:1986 Part 2, Section 6 (Compressive strength)

Specimen name: Nu-Age EZIMIX Veneer Mortar

Specimen description: Nu-Age EZIMIX veneer mortar is a pre-mixed and bagged veneer mortar to which water is added to produce a mortar suitable for construction of clay and concrete brick veneers. Further details of the assessed system are contained within the full assessment report. The report may be supplied directly by Nu-Age Plaster Ltd or for verification purposes directly by BRANZ on instruction from Nu-Age Plaster Ltd.

A full description of the testing and opinion is given in BRANZ Technical Opinion:
ST1159-TO [2016] issued 5 September 2016

Regulatory authorities are advised to examine the full technical opinion before approving any product.

The assessed result is as follows:

Mortar bond strength	>200 kPa
Mortar compressive strength	>6 MPa

Issue Date:
5 September 2016

Expiry Date:
5 September 2021